

Caribbean MOU
 The Office Centre Building
 2nd Floor,
 12 Ocean Boulevard,
 Kingston
 Jamaica W.I.



Tel: (876) 967-1077
 Fax: (876) 922-5765
 E-mail: caribmou@caribbeanmou.org
 www.caribbeanmou.org

REPORT OF CIC ON FIRE SAFETY SYSTEMS (FSS).

from **01/09/2014** to **30/11/2014**

Ship's Name / IMO No:

Port of Inspection:

Date of Inspection:

No.	Item	Yes	No	N/A
1	Is the Fire Control Plan present, permanently exhibited and up to date ? SOLAS Ch II-2/ Reg 15.2.4 (Def codes: 0755 / 07122) ¹	<input type="checkbox"/>	<input type="checkbox"/>	
2	Do the fire fighters' outfits including personal equipment comply with the requirements? SOLAS Ch II-2/ Reg 10.10 (Def codes: 0730 / 07110)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Do the Emergency Escape Breathing Devices (EEBD) comply with the requirements? SOLAS Ch II-2/ Reg 13.3.4 and Reg 13.4.3 (Def codes: 0736 / 07112)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Are the portable extinguishers ready for use in locations as per the fire control plan? SOLAS Ch II-2/Reg 10.3.2.4 (Def codes: 0720 / 07108)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5*	Does the automatic audible alarm sound prior to the release of a fixed gas fire-extinguishing medium into spaces in which personnel normally work? FSS Ch 5/ Reg 2.1.3.2 (Def codes 0725 / 07109)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6*	Are the fire protection systems, firefighting-systems and appliances maintained / ready for use? SOLAS/Ch II-2/ Reg 14.2.1 (Def codes: 0720 / 07108)	<input type="checkbox"/>	<input type="checkbox"/>	

¹ The mentioned deficiencies codes are respectively for the Caribbean MOU,CMIC- and CMIS-database

No.	Item	Yes	No	N/A
7	Is there a maintenance plan onboard, to show that fire protection systems and fire- fighting systems and appliances (as appropriate) have been properly tested and inspected? SOLAS/Ch II-2/ Reg14.2.2 (Def codes: 0720 / 07108) ¹	<input type="checkbox"/>	<input type="checkbox"/>	
8*	Does the activation of any detector or manually operated call point initiate a visual and audible fire signal at the control panel on the bridge or control station? SOLAS Ch II-2/ Reg 7.4.2 (Def codes: 0715 / 07106)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9*	Is the emergency fire pump, capable of producing at least two jets of water? SOLAS/Ch II-2/ Reg 10.2.2.3.1 and Reg 10.2.2.4.2 (Def codes: 0739 / 07113)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Are the isolating valves of the fire main marked, maintained and easily operable? SOLAS/Ch II-2/ Reg10.2.1.4 (Def codes: 0730 / 07110)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11*	Where a fire drill was witnessed was it found to be satisfactory? SOLAS Ch II-2/ Reg 15.2.2.5 and SOLAS Ch-III/ Reg 19.3 (Def codes: 2020 / 07125)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Was the ship detained as a result of the CIC?	<input type="checkbox"/>	<input type="checkbox"/>	

Notes:

If the box “No” is ticked off; than the details of the deficiencies should be appropriately entered on the PSC Report of Inspection - Form B and include the deficiency code as indicated in the question.

If the box “No” is ticked off for questions marked with an asterix “*” the ship may be considered for detention.

For statistical purposes please send the questionnaire together with the inspection report to the CMOU secretariat, caribmou@caribbeanmou.org.

¹ The mentioned deficiencies codes are respectively for the Caribbean MOU,CMIC- and CMIS-database